

Inspector: Business Representative:		Date:
	(6096 mm) and shall be isolated from contact with the public by fencing, enclosure or other <i>approved</i> means. (3104.19)  Portable fire extinguishers provided (3104.12)	Combustible waste removed from tent and area within 30 ft. of tent (3104.22)
	Generators and other internal combustion power sources shall be separated from tents or membrane structures by not less than 20 feet	structures unless otherwise <i>approved</i> by the <i>fire code official</i> . (3103.8.6)
	20 feet if open to the public (3104.7) No fireworks within 100 ft. (3104.8) 3 ft. clearance between fabric and contents (3104.11)	or fire road not less than 12 feet (3658 mm) wide and free from guy ropes or other obstructions shall be maintained on all sides of all tents and membrane
	by code official) (3103.3.9) No Smoking Signs Posted (3104.6) No cooking or open flame in or within	least 50 ft. away (3104.17)  No refueling within 20 ft. of the tent (3104.17.3)  An unobstructed fire break passageway
	components projecting below 8 feet above the exit surface.  Tent is adequately braced, anchored.  Documentation submitted (if required	protected from damage (3104.16.3)  No flammable liquids or liquid fueled equipment inside tents; storage of flammable and combustible liquids at
	or more (3103.12.6) No guy wires, ropes, or other support	LP gas containers secured and
	(3103.12.1) Exit signs provided for exits serving 50	least 10 ft. from tent (3104.16.2.1) Large (over 500 gal.) LP containers at
	Exits spaced evenly around tent	Small (under 500 gal.) LP containers at
	size, type of fabric (3104.3) Adequate number of exits provided (3103.12)	20 ft. from tents (3104.15.6) LP gas containers located outside (3104.16.2)
	Certificate from approved testing agency verifying flame resistance (3104.2)  Permanently affixed label indicating	No heating or cooking equipment within 10 ft. of exits (3104.15.3)  Outdoor cooking that produces grease laden vapors or sparks located at least